ZENIX 2MFD

X21-A *i*

FIELD UNIT FOR 2 MECHANICAL FIRE DAMPERS

- Connects 2 mechanical fire dampers (each with 2 position switches) to the bus
- Provides a terminal connection for the position switches
- Has a predefined address
- AC 230 V mains power



TECHNICAL DATA

ELECTRICAL DATA	
Nominal voltage	AC 230 V 50/60 Hz
Nominal voltage range	AC 100 230 V
For wire sizing	1 VA
Power consumption from mains	10 mW
Power consumption from bus	5 mW
Connecting	Power supply terminal 2 x 3 x max. 2.5 mm ² Position switches terminal 2 x 4 x max. 1.5 mm ² Bus terminal 2 x 4 x max. 1.5 mm ² wire
SAFETY	
Protection class	Class II (all insulated)
Degree of protection	IP54
EMC	CE according to 2004/108/EC
Low-voltage-directive	CE according to 2006/95/EC
Rated impulse voltage	2.5 kV
Control pollution degree	3
Type of action	Type 1
Software class	A
Ambient humidity range	max. 95 % r.H., non condensing
Ambient temperature range	−20 +60 °C
Non-operating temperature	−40 +85 °C
Maintenance	Maintenance-free
DIMENSIONS / WEIGHT	
Dimensions	154 x 114 x 77 mm
Weight	400 g


PRODUCT FEATURES

Monitoring of fire dampers	ZENIX 2MFD is used for monitoring up to two mechanical fire dampers (each with 2 position switches). The unit is connected to the ZENiX-controller via the 4 wire bus communication.
Predefined address	Each unit has a predefined address, no addressing required.
Work without 230 V	ZENIX 2MFD unit is able to work without 230 V, but then damper positions is not shown with the LED diodes.






WIRING AND RESOURCES



DIMENSIONS AND MOUNTING



SAFETY NOTES



- The device is not allowed to be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.
- Caution: Power supply voltage!
- It may only be installed by suitably trained personnel.
 Any legal regulations or regulations issued by authorities must be observed during assembly.
- The device may only be opened at the manufacturer's site. It does not contain any parts that can be replaced or repaired by the user.
- The device contains electrical and electronic components and is not allowed to be disposed of as household refuse. All locally valid regulations and requirements must be observed.

