


# DECLARATION OF PERFORMANCE

CE\_DoP\_Rf-t\_C16\_EN ■ G-01/02/2026

1. Unique identification code of the product-type:	CRS60
2. Intended use/es:	Circular fire damper to be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
3. Manufacturer:	Rf-Technologies NV, Lange Ambachtstraat 40, B-9860 Oosterzele
4. System/s of AVCP:	System 1
5. Harmonised standard / European Assessment Document; notified body / European Technical Assessment, Technical Assessment Body, notified body; certificate of constancy of performance:	EN 15650:2010, BCCA with identification number 0749; BCCA- 0749-CPR-BC1-606-0464-15650.20-2517
6. Declared performance according to EN 15650:2010	(Fire resistance according to EN 1366-2 and classifications according to EN 13501-3)

Essential characteristics					Performance
Range	Type	Construction	Sealing	Installation	Classification
Ø 100-630 mm	Rigid wall	Aerated concrete ≥ 100 mm	Fire resistant acrylic sealant	1	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Fire resistant acrylic sealant	2	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Fire resistant acrylic sealant	3	El 60 (v <sub>e</sub> i ↔ o) S - (500 Pa)
			Stone wool + coating with acrylic sealant	3	El 60 (v <sub>e</sub> i ↔ o) S - (500 Pa)
			Stone wool + coating with acrylic sealant	2	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Stone wool + coating ≥ 140 kg/m <sup>3</sup>	3	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Mortar / Gypsum plaster	3	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Rigid floor	Aerated concrete ≥ 100 mm	Fire resistant acrylic sealant
			Fire resistant acrylic sealant	2	El 60 (h <sub>0</sub> i ↔ o) S - (300 Pa)
			Stone wool + coating with acrylic sealant	3	El 60 (h <sub>0</sub> i ↔ o) S - (300 Pa)
			Stone wool + coating with acrylic sealant	2	El 60 (h <sub>0</sub> i ↔ o) S - (300 Pa)
	Flexible wall	Metal studs gypsum plasterboard Type A (EN 520) ≥ 100 mm	Fire resistant acrylic sealant	1	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Fire resistant acrylic sealant	2	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Fire resistant acrylic sealant	3	El 60 (v <sub>e</sub> i ↔ o) S - (500 Pa)
			Stone wool + coating with acrylic sealant	3	El 60 (v <sub>e</sub> i ↔ o) S - (500 Pa)
			Stone wool + coating with acrylic sealant	2	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Stone wool + coating ≥ 140 kg/m <sup>3</sup>	3	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Mortar / Gypsum plaster	3	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)
			Asymmetrical flexible wall (shaftwall)	Metal studs gypsum plasterboard Type F (EN 520) ≥ 80 mm	Fire resistant acrylic sealant
			Fire resistant acrylic sealant	2	El 60 (v <sub>e</sub> i ↔ o) S - (300 Pa)

1	Type of installation: surface-mounted, 0-360° (300 Pa). Minimal distances authorised.		2	Type of installation: remote from the wall, 0-360°		3	Type of installation: surface-mounted, 0-360° (300 Pa)	
---	---	---	---	--	---	---	--	---

Nominal activation conditions/sensitivity:	Pass
Response delay (response time): closure time	Pass
Operational reliability: cycling	ONE - 10000 cycles; ONE-X - 10000 cycles; BFLT - 10000 cycles; BFNT - 10000 cycles; BFLT-SR - 20000 cycles; BFNT-SR - 20000 cycles; UNIQ VD/VM FDCB ME-TA - 10000 cycles
Durability of response delay:	Pass
Durability of operational reliability:	Pass
Protection against corrosion according to EN 60068-2-52:	Pass
Damper casing leakage according to EN 1751:	≥ class ATC 3 (formerly C)

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:  
**Duchan Laplace**, R&D Manager



Oosterzele, 01/02/2026



Harmonised standard  
 EN 15650:2010